






E 8 1
TYPICAL GROUND ROD DETAIL
SCALE: NTS


TYPICAL C.O. AND TELEPHONE, DATA OUTLETS MOUNTING DETAILS



E 8 2
SCALE: NTS




PANELBOARD



RECEPTACLE BOX


SWITCH BOX

TYPICAL GROUNDING CONNECTION DETAILS
SCALE: NTS




E 8 3
SCALE: NTS


CONV. OUTLET IN SERIES WITH GCFI OUTLET WIRING CONNECTION DETAIL




PLAN



PLAN



SECTION



E 8 5
SCALE: NTS

SERVICE PEDESTAL DETAILS

DESIGN ANALYSIS						
LOAD TYPE	VA PER LOAD	VOLTAGE	PHASE CURRENT (w/ DF)			
			AB	BC	CA	3Ø
LIGHTING OUTLET	36640.00	230	85.57	24.00	49.74	0.00
CONVENIENCE OUTLET	193780.00	230	278.85	246.42	317.25	0.00
AIRCON	204981.68	230	280.50	210.00	227.00	100.30
MOTOR (NON-CONTINUOUS)	15417.85	230	0.00	0.00	0.00	38.70
MOTOR (CONTINUOUS)	0.00	230	0.00	0.00	0.00	0.00
LARGEST MOTOR	16731.61	230	0.00	0.00	0.00	42.00
SPARE	52800.00	230	26.09	140.87	52.17	6.02
TOTAL DEMAND LOAD	520351.15	230	671.00	621.29	646.17	187.03

TRANSFORMER SIZING		GENERATOR SIZING	
TOTAL LINE CURRENT	CALCULATION	kW LOAD	CALCULATION
1306.195105	TRANSFORMER SIZE $S = (1.732 \times V \times I) \times 125\%$ $S = (1.732 \times 240 \times 1306.2) \times 125\%$ $S = 678.698976455888 \text{ kVA}$		$P = (1.732 \times V \times I \times PF) / 1000$ $P = (1.732 \times 240 \times 1306.2 \times 0.80) / 1000$ $P = 434.367344931768 \text{ kW}$ $P = 434.37 \times 0.25$ $P = 108.59 \text{ kW}$ $P = 434.37 + 108.59$ $P = 542.96 \text{ kW}$
THEREFORE USE 3 x 250 KVA THREE PHASE DISTRIBUTION TRANSFORMER BANK WITH 13.2kV/7.62kV PRIMARY AND 240V SECONDARY		THEREFORE USE 2 x 300KVA 3 PHASE 240V 60HZ 0.8PF SILENT-TYPE DIESEL GENERATOR SET	

DEMAND FACTOR CALCULATION		LINE CURRENT CALCULATION	
DEMAND FACTOR = TOTAL DEMAND LOAD / TOTAL CONNECTED LOAD		$I_L = \text{TOTAL DEMAND LOAD} / (\text{VOLTAGE} \times \sqrt{3})$	
TOTAL CONNECTED (VOLT-AMPERE)		$I_L = 579111.145806997 / (230 \times \sqrt{3})$	
OVERALL DEMAND FACTOR		1306.19510480348 A	



DESIGN ANALYSIS, TRANSFORMER AND GENERATOR SIZING

SCALE:

NTS

SERVICE BUS - SCHEDULE OF LOADS																								
PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE RATING	OUTLET (VA) RATING	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT				CIRCUIT BREAKER				CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT				
												AB	BC	CA	3Ø	F	P	AT	AF	CONDUCTOR		GROUNDING		CONDUIT
SB	C1	MAIN CB					230	559671	559671	0.90	500911	671	621	646	138	60	3	1600	1600	4 x 3 - 325 mm² THWN-2 Copper Wire		1 - 100 mm² THWN-2 Copper Wire		Cable Ladder
	C2	FPP MAIN CB					230	19441	19441	1.00	19441	-	-	-	48.80	60	3	125	250	3 - 50 mm² THWN-2 Copper Wire		1 - 2 THWN-2 Copper Wire		50 mm² Conduit - RSC
TOTAL			0	0	0		230		579111	0.90	520351	671.00	621.29	646.17	187.03									

Calculation:	For Service Conductor											SERVICE CONDUCTOR										
	$I_c = [(36640 + 193780 + 16731.61) \times 125\% + 204981.68 + 15417.85 + 52800] / (230 \times \sqrt{3})$											USE: 4 sets of 3 - 325 mm² THWN-2 CU (L) + 100 mm² THWN-2 CU (EGC) @ 80 mm Ø RSC										
	$I_c = 1461.3 \text{ A}$											SERVICE PROTECTION										
												USE: 40kA, 3P, Type 1, Surge Protective Device (SPD)										

SERVICE BUS					
LOAD TYPE	DEMAND VA	DEMAND CURRENT			
		AB	BC	CA	3Ø
LIGHTING OUTLET	36640.00	85.57	24.00	49.74	0.00
CONVENIENCE OUTLET	193780.00	278.85	246.42	317.25	0.00
AIR CONDITIONING UNIT	204981.68	280.50	210.00	227.00	100.30
MOTOR	15417.85	0.00	0.00	0.00	38.70
LARGEST AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
LARGEST MOTOR	16731.61	0.00	0.00	0.00	42.00
SPARE	52800.00	26.09	140.87	52.17	6.02
TOTAL	520351.15	671.00	621.29	646.17	187.03

FIRE PROTECTION PANEL - SCHEDULE OF LOADS																						
PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE RATING	OUTLET (VA) RATING	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT					CIRCUIT BREAKER			CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT		
												AB	BC	CA	3Ø	F	AT	AF	CONDUCTOR	GROUNDING	CONDUIT	
FPP	C1	Fire Pump				15	230	16731.61	16732	1.00	16732	-	-	-	42.00	60	3	100	100	3 - 38 mm² THHN Copper Wire	1 - 14 mm² THHN Copper Wire	40 mm Ø Conduit - RSC
	C2	Jockey Pump				2	230	2708.927	2708.9	1.00	2709	-	-	-	6.80	60	3	50	50	3 - 5.5 mm² THHN Copper Wire	1 - 5.5 mm² THHN Copper Wire	20 mm Ø Conduit - RSC
	C3	SPACE						-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	C4	SPACE						-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TOTAL			0	0	0		230		19441	1.00	19441	0.00			48.80							

Calculation:	For Feeder Conductor		For Feeder Protection		FEEDER CONDUCTOR
	$I_c = [(16731.61 \times 125\%) + 2708.93] / (230 \times \sqrt{3})$		$I_{cb} = [(16731.61 \times 125\%) + 2708.93] / (230 \times \sqrt{3})$		USE: 3 - 50 mm² THWN-2 CU (L) + 1 - 14 mm² THWN-2 CU (G) @ 50 mm Ø RSC
	$I_c = 59.3 \text{ A}$		$I_{cb} = 111.8 \text{ A}$		FEEDER PROTECTION
					USE: 125AT/250AF, 230V, 60HZ, 3P, Molded Case Circuit Breaker (MCCB)
				USE: 40kA, 3P, Type 2, Surge Protective Device (SPD)	

FIRE PROTECTION PANEL					
LOAD TYPE	DEMAND VA	DEMAND CURRENT			
		AB	BC	CA	3Ø
LIGHTING OUTLET	0.00	0.00	0.00	0.00	0.00
CONVENIENCE OUTLET	0.00	0.00	0.00	0.00	0.00
AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
MOTOR	2708.93	0.00	0.00	0.00	6.80
LARGEST AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
LARGEST MOTOR	16731.61	0.00	0.00	0.00	42.00
SPARE	0.00	0.00	0.00	0.00	0.00
TOTAL	19440.54	0.00	0.00	0.00	48.80

AUTOMATIC TRANSFER SWITCH - SCHEDULE OF LOADS																						
PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE	OUTLET (VA) RATING	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT				CIRCUIT BREAKER				CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT		
												AB	BC	CA	3Ø	F	P	AT	AF	CONDUCTOR	GROUNDING	CONDUIT
ATS	C1	MDP					230	553962	553962	0.90	495802	671.00	621.29	646.17	125.40	60	3	1600	1600	4 x 3 - 325 mm ² THWN-2 Copper Wire	1 - 100 mm ² THWN-2 Copper Wire	Cable Ladder
	C2	PPB					230	5709	5709	0.89	5109	-	-	-	12.82	60	3	40	50	3 - 8.0 mm ² THHN Copper Wire	1 - 5.5mm ² THHN Copper Wire	25 mm Ø Conduit - RSC
TOTAL			0	0	0				559671	0.90	500911	671.00	621.29	646.17	138.23							

Calculation:	For Feeder Conductor		For Feeder Protection		FEEDER CONDUCTOR	
	$I_c = [(36640 + 193780 + 6440) \times 125\% + 198541.68 + 12708.93 + 52800] / (230 \times \sqrt{3})$		$I_{cb} = [(6440 \times 225\%) + (36640 + 193780) \times 125\% + 198541.68 + 12708.93 + 52800] / (230 \times \sqrt{3})$		USE: 4 sets of 3 - 325 mm ² THWN-2 CU (L) + 1 - 100 mm ² THWN-2 CU (EGC) @ Cable Ladder	
	$I_c = 1406.04 \text{ A}$		$I_{cb} = 1422.2 \text{ A}$		AUTOMATIC TRANSFER SWITCH	
					USE: 1600AT/1600AF, 230V, 60HZ, 3P, Molded Case Circuit Breaker (MCCB)	


AUTOMATIC TRANSFER SWITCH					
LOAD TYPE	DEMAND VA	DEMAND CURRENT			
		AB	BC	CA	3Ø
LIGHTING OUTLET	36640.00	85.57	24.00	49.74	0.00
CONVENIENCE OUTLET	193780.00	278.85	246.42	317.25	0.00
AIR CONDITIONING UNIT	198541.68	252.50	210.00	227.00	100.30
MOTOR	12708.93	0.00	0.00	0.00	31.90
LARGEST AIR CONDITIONING UNIT	6440.00	28.00	0.00	0.00	0.00
LARGEST MOTOR	0.00	0.00	0.00	0.00	0.00
SPARE	52800.00	26.09	140.87	52.17	6.02
TOTAL	500910.61	671.00	621.29	646.17	138.23



SCHEDULE OF LOADS

SCALE:

NTS



REPUBLIC OF THE PHILIPPINES
UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES
CAGAYAN DE ORO CAMPUS
INFRASTRUCTURE PLANNING AND FACILITY DEVELOPMENT UNIT
CLARO M. RECTO AVENUE, LAPASAN, CAGAYAN DE ORO CITY 9000
TELEPHONE # (0822) 72-60-65 / (080) 856-1738 / 856-1739 | TELE FAX (080) 856-4696
WEBSITE: www.ustp.edu.ph

PROFESSIONAL ELECTRICAL ENGINEER
PROJECT
LOCATION
OWNER

PROPOSED ESTABLISHMENT OF 3-STORY SMART COMPUTING
ACADEMIC BUILDING PHASE 1, OROQUETA CAMPUS
USTP OROQUETA CAMPUS, MOROD, MISAMIS OCCIDENTAL
UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES

RECOMMENDING APPROVAL:
ENGR. GRACE C. BABA
DIRECTOR, INFRASTRUCTURE PLANNING & FACILITIES DEVELOPMENT OFFICE

RECOMMENDING APPROVAL:
DR. GLORIMER L. CLARIN
CAMPUS DIRECTOR, OROQUETA CAMPUS

APPROVED BY:
ATTY. JONATHAN S. OCHE
VP FOR ADMINISTRATION & LEGAL AFFAIRS

APPROVED BY:
DR. AMBROSIO B. CULTURA II
PRESIDENT, USTP SYSTEM

SHEET CONTENTS:
DESIGN ANALYSIS, TRANSFORMER AND GENERATOR SIZING
SCHEDULE OF LOADS

DRAWN BY:
DATE DRAWN:
05.01.2026
FNT:

MAIN DISTRIBUTION PANEL - SCHEDULE OF LOADS

PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE RATING	OUTLET (VA) RATING	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT				CIRCUIT BREAKER				CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT		
												AB	BC	CA	3Ø	F	P	AT	AF	CONDUCTOR	GROUNDING	CONDUIT
MDP	C1	PB1					230	45800	45800	0.84	38620	59.18	55.20	53.53	-	60	3	125	250	3 - 50 mm ² THHN Copper Wire	1 - 14 mm ² THHN Copper Wire	50 mm Ø Conduit - EMT
	C2	PB2					230	24520	24520	0.86	21164	32.77	28.00	31.25	-	60	3	100	100	3 - 38 mm ² THHN Copper Wire	1 - 14 mm ² THHN Copper Wire	40 mm Ø Conduit - EMT
	C3	PB2A					230	30980	30980	0.81	25156	35.20	38.26	35.91	-	60	3	100	100	3 - 38 mm ² THHN Copper Wire	1 - 14 mm ² THHN Copper Wire	40 mm Ø Conduit - EMT
	C4	PB2B					230	30980	30980	0.81	25156	35.20	38.26	35.91	-	60	3	100	100	3 - 38 mm ² THHN Copper Wire	1 - 14 mm ² THHN Copper Wire	40 mm Ø Conduit - EMT
	C5	PB2C					230	30980	30980	0.81	25156	35.20	38.26	35.91	-	60	3	100	100	3 - 38 mm ² THHN Copper Wire	1 - 14 mm ² THHN Copper Wire	40 mm Ø Conduit - EMT
	C6	PB2D					230	30980	30980	0.81	25156	35.20	38.26	35.91	-	60	3	100	100	3 - 38 mm ² THHN Copper Wire	1 - 14 mm ² THHN Copper Wire	40 mm Ø Conduit - EMT
	C7	PB2E					230	31280	31280	0.83	25924	28.37	38.26	46.09	-	60	3	100	100	3 - 38 mm ² THHN Copper Wire	1 - 14 mm ² THHN Copper Wire	40 mm Ø Conduit - EMT
	C8	PB3					230	27500	27500	0.85	23500	32.82	37.58	31.77	-	60	3	100	100	3 - 38 mm ² THHN Copper Wire	1 - 14 mm ² THHN Copper Wire	40 mm Ø Conduit - EMT
	C9	PB3A					230	28150	28150	0.82	23104	35.43	29.63	35.39	-	60	3	100	100	3 - 38 mm ² THHN Copper Wire	1 - 14 mm ² THHN Copper Wire	40 mm Ø Conduit - EMT
	C10	PB3B					230	36800	36800	0.81	29884	45.50	43.48	40.96	-	60	3	100	100	3 - 38 mm ² THHN Copper Wire	1 - 14 mm ² THHN Copper Wire	40 mm Ø Conduit - EMT
	C11	APB1					230	65100	65100	0.99	64500	100.43	101.00	79.00	-	60	3	200	250	3 - 100 mm ² THHN Copper Wire	1 - 22 mm ² THHN Copper Wire	50 mm Ø Conduit - EMT
	C12	APB2					230	82925	82925	0.99	82325	154.50	81.00	122.43	-	60	3	250	250	3 - 150 mm ² THHN Copper Wire	1 - 22 mm ² THHN Copper Wire	65 mm Ø Conduit - EMT
	C13	APB3					230	65957	65957	0.99	65357	41.22	33.22	36.00	100.30	60	3	200	250	3 - 100 mm ² THHN Copper Wire	1 - 22 mm ² THHN Copper Wire	50 mm Ø Conduit - EMT
	C14	Elevator					230	10000	10000	1.00	10000	-	-	-	25.10	60	3	60	100	3 - 14 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	25 mm Ø Conduit - EMT
	C15	Fire Alarm Control Panel					230	3000	3000	1.00	3000	-	-	13.04	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C16	CCTV System					230	3000	3000	1.00	3000	-	-	13.04	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C17	SPARE					230	3000	3000	0.80	2400	-	10.43	-	-	60	2	20	50	-	-	-
	C18	SPARE					230	3000	3000	0.80	2400	-	10.43	-	-	60	2	20	50	-	-	-
	C19	SPACE					-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	C20	SPACE					-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TOTAL			0	0	0	0	230		553962	0.90	495802	671.00	621.29	646.17	125.4							

Calculation:

For Feeder Conductor	For Feeder Protection	FEEDER CONDUCTOR
$I_c = [(36640 + 193780 + 6440) \times 125\% + 198541.68 + 10000 + 50400] / (230 \times \sqrt{3})$	$I_{cb} = [(6440 \times 225\%) + (36640 + 193780) \times 125\% + 198541.68 + 10000 + 50400] / (230 \times \sqrt{3})$	USE: 4 sets of 3 - 50 mm ² THWN-2 CU (L) + 1 - 100 mm ² THWN-2 CU (G) @ Cable Ladder
$I_c = 1393.21 \text{ A}$	$I_{cb} = 1409.38 \text{ A}$	FEEDER PROTECTION USE: 1600A/50AF, 230V, 60HZ, 3P, Molded Case Circuit Breaker (MCCB) USE: 100kA, 3P, Type 2, Surge Protective Device (SPD)

PLUMBING PANEL BOARD - SCHEDULE OF LOADS

PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE RATING	OUTLET (VA) RATING	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT				CIRCUIT BREAKER				CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT		
												AB	BC	CA	3Ø	F	P	AT	AF	CONDUCTOR	GROUNDING	CONDUIT
PPB	C1	Plumbing Transfer Pump				2	230	2708.927	2708.9	1.00	2709	-	-	-	-	60	3	30	50	5.5 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	20 mm Ø Conduit - RSC
	C2	SPARE					230	3000	3000	0.80	2400	-	-	-	-	-	-	-	-	-	-	-
	C3	SPACE					-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	C4	SPACE					-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TOTAL			0	0	0		230		5709	0.89	5109	0.00	0.00	0.00	12.82							

Calculation:


For Feeder Conductor	For Feeder Protection	FEEDER CONDUCTOR
$I_c = [(2708.93 \times 125\%) + 2400] / (230 \times \sqrt{3})$	$I_{cb} = [(2708.93 \times 250\%) + 2400] / (230 \times \sqrt{3})$	USE: 3 - 8.0 mm ² THWN-2 CU (L) + 1 - 5.5 mm ² THWN-2 CU (G) @ 25 mm Ø RSC
$I_c = 14.52 \text{ A}$	$I_{cb} = 23.02 \text{ A}$	FEEDER PROTECTION USE: 40AT/50AF, 230V, 60HZ, 3P, Molded Case Circuit Breaker (MCCB) USE: 40kA, 3P, Type 2, Surge Protective Device (SPD)

MAIN DISTRIBUTION PANEL

LOAD TYPE	DEMAND VA	DEMAND CURRENT			
		AB	BC	CA	3Ø
LIGHTING OUTLET	36640.00	85.57	24.00	49.74	0.00
CONVENIENCE OUTLET	193780.00	278.85	246.42	317.25	0.00
AIR CONDITIONING UNIT	198541.68	252.50	210.00	227.00	100.30
MOTOR	10000.00	0.00	0.00	0.00	25.10
LARGEST AIR CONDITIONING UNIT	6440.00	28.00	0.00	0.00	0.00
LARGEST MOTOR	0.00	0.00	0.00	0.00	0.00
SPARE	50400.00	20.09	140.87	52.17	0.00
TOTAL	495801.68	571.00	621.29	646.17	125.40

PLUMBING PANEL BOARD

LOAD TYPE	DEMAND VA	DEMAND CURRENT			
		AB	BC	CA	3Ø
LIGHTING OUTLET	0.00	0.00	0.00	0.00	0.00
CONVENIENCE OUTLET	0.00	0.00	0.00	0.00	0.00
AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
MOTOR	0.00	0.00	0.00	0.00	0.00
LARGEST AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
LARGEST MOTOR	2708.93	0.00	0.00	0.00	6.80
SPARE	2400.00	0.00	0.00	0.00	6.02
TOTAL	5108.93	0.00	0.00	0.00	12.82



REPUBLIC OF THE PHILIPPINES
UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES
CAGAYAN DE ORO CAMPUS
INFRASTRUCTURE PLANNING AND FACILITY DEVELOPMENT UNIT
CLARO M. RECTO AVENUE, LAPASAN, CAGAYAN DE ORO CITY 9000
TELEPHONE # (08822) 72-60-65 / (088) 856-1738 / 856-1739 | TELE FAX (088) 856-4696
WEBSITE: www.ustp.edu.ph

PROFESSIONAL ELECTRICAL ENGINEER

PROJECT

PROPOSED ESTABLISHMENT OF 3-STORY SMART COMPUTING
ACADEMIC BUILDING PHASE 1, OROQUIETA CAMPUS

LOCATION

USTP OROQUIETA CAMPUS, MOBOD, MISAMIS OCCIDENTAL

OWNER

UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES

RECOMMENDING APPROVAL:

ENGR. GRACE C. BABA

DIRECTOR, INFRASTRUCTURE PLANNING & FACILITY DEVELOPMENT OFFICE

RECOMMENDING APPROVAL:

DR. GLOMER L. CLARIN

CAMPUS DIRECTOR, USTP OROQUIETA CAMPUS

APPROVED BY:

ATTY. JONATHAN S. OCHE

VP FOR ADMINISTRATION & LEGAL AFFAIRS

APPROVED BY:

DR. AMBROSIO B. CULTURA II

PRESIDENT, USTP SYSTEM

SHEET CONTENTS:

SCHEDULE OF LOADS

DRAWN BY:

DATE DRAWN:

05.01.2026

EXT:

E10

PANEL BOARD 1 - SCHEDULE OF LOADS

PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE RATING	OUTLET (VA)	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT				CIRCUIT BREAKER				CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT		
												AB	BC	CA	3Ø	F	P	AT	AF	CONDUCTOR	GROUNDING	CONDUIT
PB1	C1	Lighting Outlet	14				230	100	1400	0.80	1120	4.87	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C2	Lighting Outlet	14				230	100	1400	0.80	1120	4.87	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C3	Lighting Outlet	14				230	100	1400	0.80	1120	-	-	4.87	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C4	Lighting Outlet	14				230	100	1400	0.80	1120	-	-	4.87	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C5	Lighting Outlet	12				230	100	1200	0.80	960	-	4.17	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C6	Lighting Outlet	22				230	100	2200	0.80	1760	-	7.65	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C7	Lighting Outlet	14				230	100	1400	0.80	1120	4.87	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C8	Lighting Outlet	16	1			230	100	1700	0.80	1360	5.91	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C9	Lighting Outlet	9				230	100	900	0.80	720	-	-	3.13	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C10	Lighting Outlet	8				230	100	800	0.80	640	-	-	2.78	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C11	Lighting Outlet	5				230	100	500	0.80	400	-	1.74	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C12	Convenience Outlet		12			230	180	2160	0.80	1728	-	7.51	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C13	Convenience Outlet		12			230	180	2160	0.80	1728	7.51	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C14	Convenience Outlet		12			230	180	2160	0.80	1728	7.51	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C15	Convenience Outlet		12			230	180	2160	0.80	1728	-	-	7.51	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C16	Convenience Outlet		9			230	180	1620	0.80	1296	-	-	5.63	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C17	Convenience Outlet		9			230	180	1620	0.80	1296	-	-	5.63	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C18	Convenience Outlet		8			230	180	1440	0.80	1152	-	5.01	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C19	Convenience Outlet		7			230	180	1260	0.80	1008	4.38	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C20	Convenience Outlet		7			230	180	1260	0.80	1008	4.38	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C21	Convenience Outlet		7			230	180	1260	0.80	1008	-	-	4.38	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C22	Convenience Outlet - Server		1			230	1500	1500	1.00	1500	-	-	6.52	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C23	Convenience Outlet - Server		1			230	1500	1500	1.00	1500	-	-	6.52	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C24	Convenience Outlet - Server		1			230	1500	1500	1.00	1500	-	-	6.52	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C25	Convenience Outlet - Emergency Lighting		10			230	180	1800	1.00	1800	-	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C26	Convenience Outlet - Emergency Lighting		9			230	180	1620	1.00	1620	-	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C27	Convenience Outlet - Emergency Lighting		11			230	180	1980	1.00	1980	-	-	8.61	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C28	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
	C29	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
	C30	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
TOTAL			142	37	0		230		45800	0.84	38620	59.18	55.20	53.53	0							

Calculation:

For Feeder Conductor and Protection

$$I_{cb} = \frac{10000 \times (0 + 23580) \times 125\% + 3600}{(230 \times \sqrt{3})}$$

$$I_{cb} = 118.92 \text{ A}$$

FEEDER CONDUCTOR

USE: 3 - 50 mm² THHN CU (L) + 1 - 14 mm² THHN CU (EGC) @ 50 mm Ø EMT

FEEDER PROTECTION

USE: 125AT/250AF, 230V, 60HZ, 3P, Molded Case Circuit Breaker (MCCB)

USE: 40kA, 3P, Type 2, Surge Protective Device (SPD)

PANEL BOARD 1

DEMAND VA	VA	DEMAND CURRENT			
		AB	BC	CA	3Ø
LIGHTING OUTLET	11440.00	20.52	13.57	15.65	0.00
CONVENIENCE OUTLET	23580.00	38.66	31.20	32.66	0.00
AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
MOTOR	0.00	0.00	0.00	0.00	0.00
LARGEST AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
LARGEST MOTOR	0.00	0.00	0.00	0.00	0.00
SPARE	3600.00	0.00	10.43	5.22	0.00
TOTAL	38620.00	59.18	55.20	53.53	0.00

PANEL BOARD 2 - SCHEDULE OF LOADS

PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE RATING	OUTLET (VA)	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT				CIRCUIT BREAKER				CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT		
												AB	BC	CA	3Ø	F	P	AT	AF	CONDUCTOR	GROUNDING	CONDUIT
	C1	Lighting Outlet	17				230	100	1700	0.80	1360	5.91	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C2	Lighting Outlet	13				230	100	1300	0.80	1040	4.52	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C3	Lighting Outlet	12	1			230	100	1300	0.80	1040	-	-	4.52	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C4	Lighting Outlet	14				230	100	1400	0.80	1120	-	-	-	4.87	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C5	Lighting Outlet	8				230	100	800	0.80	640	-	2.78	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C6	Lighting Outlet	5				230	100	500	0.80	400	-	1.74	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C7	Convenience Outlet		7			230	180	1260	0.80	1008	4.38	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C8	Convenience Outlet		7			230	180	1260	0.80	1008	4.38	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C9	Convenience Outlet		7			230	180	1260	0.80	1008	-	-	4.38	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
PB2	C10	Convenience Outlet - Small Appliance		1			230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C11	Convenience Outlet - Refrigerator		1			230	1500	1500	1.00	1500	-	6.52	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C12	Convenience Outlet - Server		1			230	1500	1500	1.00	1500	-	6.52	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C13	Convenience Outlet - Server		1			230	1500	1500	1.00	1500	6.52	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C14	Convenience Outlet - Emergency Lighting		9			230	180	1620	1.00	1620	7.04	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C15	Convenience Outlet - Emergency Lighting		9			230	180	1620	1.00	1620	-	-	7.04	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C16	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C17	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C18	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C19	SPARE					-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	C20	SPARE					-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	TOTAL		69	23	0		230		24520	0.86	21164	32.77	28.00	31.25	0							

Calculation:

For Feeder Conductor and Protection

$$I_{cb} = [(5600 + 11964) \times 125\% + 4800] / \sqrt{3}$$

$$I_{cb} = 64.15 \text{ A}$$

FEEDER CONDUCTOR

USE: 3 - 38 mm² THHN CU (L) + 1 - 14 mm² THHN CU (EGC) @ 40 mm Ø EMT

FEEDER PROTECTION

USE: 100AT/100AF, 230V, 60HZ, 3P, Molded Case Circuit Breaker (MCCB)

USE: 40kA, 3P, Type 2, Surge Protective Device (SPD)

PANEL BOARD 2A, 2B, 2C, 2D - SCHEDULE OF LOADS

PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE RATING	OUTLET (VA)	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT				CIRCUIT BREAKER				CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT		
												AB	BC	CA	3Ø	F	P	AT	AF	CONDUCTOR	GROUNDING	CONDUIT
	C1	Lighting Outlet	14				230	100	1400	0.80	1120	4.87	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C2	Convenience Outlet - Computer		4	8		230	500	4000	0.80	3200	13.91	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C3	Convenience Outlet - Computer		4	8		230	500	4000	0.80	3200	-	-	13.91	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C4	Convenience Outlet - Computer		8			230	500	4000	0.80	3200	-	-	13.91	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
PB2A	C5	Convenience Outlet - Computer		8			230	500	4000	0.80	3200	-	13.91	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
PB2B	C6	Convenience Outlet - Computer		4	8		230	500	4000	0.80	3200	-	-	13.91	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
PB2C	C7	Convenience Outlet - Computer		4	8		230	500	4000	0.80	3200	13.91	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
PB2D	C8	Convenience Outlet - Server		4			230	180	720	0.80	576	2.50	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C9	Convenience Outlet - Server		1			230	1500	1500	1.00	1500	-	-	6.52	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C10	Convenience Outlet - Emergency Lighting		2			230	180	360	1.00	360	-	-	1.57	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C11	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C12	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	TOTAL		14	31	48		230		30980	0.81	25156	35.20	38.26	35.91	0							

Calculation:

For Feeder Conductor and Protection

$$I_{cb} = [(1120 + 21636) \times 125\% + 2400] / (230 \times \sqrt{3})$$

$$I_{cb} = 77.43 \text{ A}$$

FEEDER CONDUCTOR

USE: 3 - 38 mm² THHN CU (L) + 1 - 14 mm² THHN CU (EGC) @ 40 mm Ø EMT


FEEDER PROTECTION

USE: 100AT/100AF, 230V, 60HZ, 3P, Molded Case Circuit Breaker (MCCB)

USE: 40kA, 3P, Type 2, Surge Protective Device (SPD)

PANEL BOARD 2A-2D

LOAD TYPE	DEMAND VA	DEMAND CURRENT			
		AB	BC	CA	3Ø
LIGHTING OUTLET	1120.00	4.87	0.00	0.00	0.00
CONVENIENCE OUTLET	21636.00	30.33	27.83	35.91	0.00
AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
MOTOR	0.00	0.00	0.00	0.00	0.00
LARGEST AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
LARGEST MOTOR	0.00	0.00	0.00	0.00	0.00
SPARE	2400.00	0.00	10.43	0.00	0.00
TOTAL	25156.00	35.20	38.26	35.91	0.00



REPUBLIC OF THE PHILIPPINES
UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES
CAGAYAN DE ORO CAMPUS
INFRASTRUCTURE PLANNING AND FACILITY DEVELOPMENT UNIT
CLARO M. RECTO AVENUE, LAPASAN, CAGAYAN DE ORO CITY 9000
TELEPHONE # (0822) 72-60-65 / (088) 856-1738 / 856-1739 | TELE FAX (088) 856-4695
WEBSITE: www.ustp.edu.ph

PROFESSIONAL ELECTRICAL ENGINEER

PROJECT

PROPOSED ESTABLISHMENT OF 3-STORY SMART COMPUTING
ACADEMIC BUILDING PHASE 1, OROQUETA CAMPUS

LOCATION

USTP OROQUETA CAMPUS, MOROD, MISAMIS OCCIDENTAL

OWNER

UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES

RECOMMENDING APPROVAL:

ENGR. GRACE C. BABA

DIRECTOR, INFRASTRUCTURE PLANNING & FACILITIES DEVELOPMENT OFFICE

RECOMMENDING APPROVAL:

DR. GLOMER L. CLARIN

CAMPUS DIRECTOR, USTP OROQUETA CAMPUS

APPROVED BY:

ATTY. JONATHAN S. OCHE

VP FOR ADMINISTRATION & LEGAL AFFAIRS

APPROVED BY:

DR. AMBROSIO B. CULTURA II

PRESIDENT, USTP SYSTEM

SHEET CONTENTS:

SCHEDULE OF LOADS

DRAWN BY:

DATE DRAWN:

05.01.2026

FILE:

E12

PANEL BOARD 2E - SCHEDULE OF LOADS

PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE RATING	OUTLET (VA) RATING	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT				CIRCUIT BREAKER				CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT		
												AB	BC	CA	3Ø	F	P	AT	AF	CONDUCTOR	GROUNDING	CONDUIT
PB2E	C1	Lighting Outlet	12				230	100	1200	0.80	960	4.17	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C2	Convenience Outlet - Computer		4	8		230	500	4000	0.80	3200	13.91	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C3	Convenience Outlet - Computer		4	8		230	500	4000	0.80	3200	-	-	13.91	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C4	Convenience Outlet - Computer		4	8		230	500	4000	0.80	3200	-	-	13.91	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C5	Convenience Outlet - Computer		4	8		230	500	4000	0.80	3200	-	13.91	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C6	Convenience Outlet - Computer		4	8		230	500	4000	0.80	3200	-	13.91	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C7	Convenience Outlet		6			230	180	1080	0.80	864	3.76	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C8	Convenience Outlet - Server		1			230	1500	1500	1.00	1500	6.52	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C9	Convenience Outlet - Emergency Lighting		2			230	1500	3000	1.00	3000	-	-	13.04	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C10	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C11	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
	C12	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
TOTAL			12	29	40		230		31280	0.83	25924	28.37	38.26	46.09	0							

Calculation:

For Feeder Conductor and Protection

$$I_{cb} = [(960 + 21364) \times 125\% + 3600] / (230 \times \sqrt{3})$$

$$I_{cb} = 79.08 \text{ A}$$

FEEDER CONDUCTOR

USE: 3 - 38 mm² THHN CU (L) + 1 - 14 mm² THHN CU (E) @ 40 mm Ø

FEEDER PROTECTION

USE: 100AT, 100AF, 230V, 60HZ, 3P, Molded Case Circuit Breaker (MCCB)

USE: 40kA, 3P, Type 2, Surge Protective Device (SPD)

PANEL BOARD 2E					
LOAD TYPE	DEMAND VA	DEMAND CURRENT			
		AB	BC	CA	3Ø
LIGHTING OUTLET	960.00	4.17	-	-	0.00
CONVENIENCE OUTLET	21364.00	13.91	-	13.91	40.87
AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
MOTOR	0.00	0.00	0.00	0.00	0.00
LARGEST AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
SPARE	3600.00	0.00	0.00	10.43	5.22
TOTAL	25924.00	28.37	38.26	46.09	0.00

PANEL BOARD 3 - SCHEDULE OF LOADS

PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE RATING	OUTLET (VA) RATING	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT				CIRCUIT BREAKER				CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT		
												AB	BC	CA	3Ø	F	P	AT	AF	CONDUCTOR	GROUNDING	CONDUIT
PB3	C1	Lighting Outlet	15				230	100	1500	0.80	1200	5.22	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C2	Lighting Outlet	15				230	100	1500	0.80	1200	5.22	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C3	Lighting Outlet	18				230	100	1800	0.80	1440	-	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C4	Lighting Outlet	12				230	100	1200	0.80	960	-	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C5	Lighting Outlet	16	1			230	100	1700	0.80	1360	-	5.91	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C6	Convenience Outlet		11			230	180	1980	0.80	1584	-	6.89	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C7	Convenience Outlet		10			230	180	1800	0.80	1440	6.26	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C8	Convenience Outlet		7			230	180	1260	0.80	1008	4.38	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C9	Convenience Outlet		7			230	180	1260	0.80	1008	-	4.38	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C10	Convenience Outlet - Server		1			230	1500	1500	1.00	1500	-	-	6.52	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C11	Convenience Outlet - Server		1			230	1500	1500	1.00	1500	6.52	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C12	Convenience Outlet - Emergency Lighting		10			230	1800	1800	1.00	1800	7.83	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C13	Convenience Outlet - Emergency Lighting		9			230	1800	1620	1.00	1620	7.04	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C14	Convenience Outlet - Emergency Lighting		6			230	1800	1080	1.00	1080	4.70	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C15	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C16	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C17	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
	C18	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
	C19	SPACE					-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	C20	SPACE					-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TOTAL			63	0			230		27500	0.85	23500	32.82	37.58	31.77	0							

Calculation:

For Feeder Conductor and Protection

$$I_{cb} = [(1200 + 12540) \times 125\% + 4800] / (230 \times \sqrt{3})$$

$$I_{cb} = 70.73 \text{ A}$$

FEEDER CONDUCTOR

USE: 3 - 38 mm² THHN CU (L) + 1 - 14 mm² THHN CU (E) @ 40 mm Ø EMT

FEEDER PROTECTION

USE: 100AT/100AF, 230V, 60HZ, 3P, Molded Case Circuit Breaker (MCCB)

USE: 40kA, 3P, Type 2, Surge Protective Device (SPD)

PANEL BOARD 3					
LOAD TYPE	DEMAND VA	DEMAND CURRENT			
		AB	BC	CA	3Ø
LIGHTING OUTLET	6160.00	10.43	5.91	10.43	0.00
CONVENIENCE OUTLET	12540.00	22.38	21.23	10.90	0.00
AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
MOTOR	0.00	0.00	0.00	0.00	0.00
LARGEST AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
LARGEST MOTOR	0.00	0.00	0.00	0.00	0.00
SPARE	4800.00	0.00	10.43	10.43	0.00
TOTAL	23500.00	32.82	37.58	31.77	0.00



REPUBLIC OF THE PHILIPPINES
UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES
CAGAYAN DE ORO CAMPUS
INFRASTRUCTURE PLANNING AND FACILITY DEVELOPMENT UNIT
CLARO H. RECTO AVENUE, LAPASAN, CAGAYAN DE ORO CITY 9000
TELEPHONE # (08822) 72-60-65 / (088) 856-1738 / 856-1739 | TELE FAX (088) 856-4695
WEBSITE: www.ustp.edu.ph

PROFESSIONAL ELECTRICAL ENGINEER

PROJECT

PROPOSED ESTABLISHMENT OF 3-STORY SMART COMPUTING
ACADEMIC BUILDING PHASE 1, OROQUETA CAMPUS

LOCATION

USTP OROQUETA CAMPUS, MOROD, MISAMIS OCCIDENTAL

OWNER

UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES

RECOMMENDING APPROVAL:

ENGR. GRACE C. BABA

DIRECTOR, INFRASTRUCTURE PLANNING & FACILITY DEVELOPMENT OFFICE

RECOMMENDING APPROVAL:

DR. GLORIMER L. CLARIN

CAMPUS DIRECTOR, USTP OROQUETA CAMPUS

ATTY. JONATHAN S. OCHE

VP FOR ADMINISTRATION & LEGAL AFFAIRS

APPROVED BY:

DR. AMBROSIO B. CULTURA II

PRESIDENT, USTP SYSTEM

SHEET CONTENTS:

SCHEDULE OF LOADS

DRAWN BY:

DATE DRAWN:

05.01.2026

EXT:

E13

PANEL BOARD 3A - SCHEDULE OF LOADS

PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE RATING	OUTLET (VA)	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT				CIRCUIT BREAKER				CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT		
												AB	BC	CA	3Ø	F	P	AT	AF	CONDUCTOR	GROUNDING	CONDUIT
PB3A	C1	Lighting Outlet	16				230	100	1600	0.80	1280	5.57	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C2	Lighting Outlet	23				230	100	2300	0.80	1840	8.00	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C3	Lighting Outlet	21				230	100	2100	0.80	1680	-	-	7.30	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C4	Lighting Outlet	20				230	100	2000	0.80	1600	-	-	6.96	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C5	Convenience Outlet		7			230	180	1260	0.80	1008	-	4.38	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C6	Convenience Outlet		7			230	180	1260	0.80	1008	-	4.38	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C7	Convenience Outlet		7			230	180	1260	0.80	1008	4.38	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C8	Convenience Outlet - Emergency Lighting		9			230	180	1620	1.00	1620	7.04	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C9	Convenience Outlet - Emergency Lighting		7			230	180	1260	1.00	1260	-	-	5.48	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C10	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C11	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
	C12	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
	C13	SPARE					230	1500	1500	0.80	1200	5.22	-	-	-	60	2	20	50	-	-	-
	C14	SPARE					230	1500	1500	0.80	1200	5.22	-	-	-	60	2	20	50	-	-	-
	C15	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
	C16	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
	C17	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
	C18	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
TOTAL			80	37	0		230		28160	0.82	23104	35.43	29.63	35.39	0.00							

Calculation:

For Feeder Conductor and Protection

$$I_{cb} = [(6400 + 5904) \times 125\% + 10800] / (230 \times \sqrt{3})$$

$$I_{cb} = 65.72$$

FEEDER CONDUCTOR

USE: 3 - 35 mm² THHN CU (L) + 1 - 14 mm² THHN CU (G) @ 40 mm Ø EMT

FEEDER PROTECTION

USE: 100AT/100AF, 230V, 60HZ, 3P, Molded Case Circuit Breaker (MCCB)

USE: 40kA, 3P, Type 2, Surge Protective Device (SPD)

PANEL BOARD 3B - SCHEDULE OF LOADS

PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE RATING	OUTLET (VA)	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT				CIRCUIT BREAKER				CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT		
												AB	BC	CA	3Ø	F	P	AT	AF	CONDUCTOR	GROUNDING	CONDUIT
PB3B	C1	Lighting Outlet	20				230	100	1600	0.80	1280	6.96	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C2	Convenience Outlet - Computer		5	10		230	100	1600	0.80	1280	17.39	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C3	Convenience Outlet - Computer		5	10		230	100	1600	0.80	1280	-	-	17.39	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C4	Convenience Outlet - Computer		8			230	500	4000	0.80	3200	-	-	13.91	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C5	Convenience Outlet - Computer		4			230	500	4000	0.80	3200	-	15.65	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C6	Convenience Outlet - Computer		4			230	500	4000	0.80	3200	-	17.39	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C7	Convenience Outlet - Computer		5			230	500	4000	0.80	3200	17.39	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C8	Convenience Outlet					230	180	1080	0.80	864	3.76	-	-	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C9	Convenience Outlet - Server					230	1500	1500	1.00	1500	-	-	6.52	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C10	Convenience Outlet - Emergency Lighting		4			230	180	1620	1.00	1620	-	-	3.13	-	60	2	20	50	2 - 3.5 mm ² THHN Copper Wire	1 - 3.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C11	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
	C12	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
TOTAL			20	38	57		230		36800	0.81	29884	45.50	43.48	40.96	0							

Calculation:

For Feeder Conductor and Protection

$$I_{cb} = [(1600 + 25884) \times 125\% + 2400] / (230 \times \sqrt{3})$$

$$I_{cb} = 92.26 \text{ A}$$

FEEDER CONDUCTOR

USE: 3 - 38 mm² THHN CU (L) + 1 - 14 mm² THHN CU (G) @ 40 mm Ø EMT

FEEDER PROTECTION

USE: 100AT/100AF, 230V, 60HZ, 3P, Molded Case Circuit Breaker (MCCB)


USE: 40kA, 3P, Type 2, Surge Protective Device (SPD)

PANEL BOARD 3A

LOAD TYPE	DEMAND VA	DEMAND CURRENT			
		AB	BC	CA	3Ø
LIGHTING OUTLET	6400.00	13.57	0.00	14.26	0.00
CONVENIENCE OUTLET	5904.00	11.43	8.77	5.48	0.00
AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
MOTOR	0.00	0.00	0.00	0.00	0.00
LARGEST AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
LARGEST MOTOR	0.00	0.00	0.00	0.00	0.00
SPARE	10800.00	10.43	20.87	15.65	0.00
TOTAL	23104.00	35.43	29.63	35.39	0.00

PANEL BOARD 3B

LOAD TYPE	DEMAND VA	DEMAND CURRENT			
		AB	BC	CA	3Ø
LIGHTING OUTLET	1600.00	6.96	0.00	0.00	0.00
CONVENIENCE OUTLET	25884.00	38.54	33.04	40.96	0.00
AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
MOTOR	0.00	0.00	0.00	0.00	0.00
LARGEST AIR CONDITIONING UNIT	0.00	0.00	0.00	0.00	0.00
LARGEST MOTOR	0.00	0.00	0.00	0.00	0.00
SPARE	2400.00	0.00	10.43	0.00	0.00
TOTAL	29884.00	45.50	43.48	40.96	0.00



REPUBLIC OF THE PHILIPPINES
UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES
CAGAYAN DE ORO CAMPUS
INFRASTRUCTURE PLANNING AND FACILITY DEVELOPMENT UNIT
CLARO M. RECTO AVENUE, LAPASAN, CAGAYAN DE ORO CITY 9000
TELEPHONE: (08822) 72-60-65 / (088) 856-1738 / 856-1739 | TELE FAX: (088) 856-4896
WEBSITE: www.ustp.edu.ph

PROFESSIONAL ELECTRICAL ENGINEER

PROJECT

PROPOSED ESTABLISHMENT OF 3-STORY SMART COMPUTING
ACADEMIC BUILDING PHASE 1, OROQUIETA CAMPUS

LOCATION

USTP OROQUIETA CAMPUS, MOBOD, MISAMIS OCCIDENTAL

OWNER

UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES

RECOMMENDING APPROVAL:

ENGR. GRACE C. BABA

DIRECTOR, INFRASTRUCTURE PLANNING & FACILITY DEVELOPMENT OFFICE

RECOMMENDING APPROVAL:

DR. GLOMER L. CLABIN

CAMPUS DIRECTOR, USTP OROQUIETA CAMPUS

APPROVED BY:

ATTY. JONATHAN S. OCHE

VP FOR ADMINISTRATION & LEGAL AFFAIRS

APPROVED BY:

DR. AMBROSIO B. CULTURA II

PRESIDENT, USTP SYSTEM

SHEET CONTENTS:

SCHEDULE OF LOADS

DRAWN BY:

DATE DRAWN:

05.01.2026

ENT:

E14

ACU PANEL BOARD 1 - SCHEDULE OF LOADS

PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE RATING	OUTLET (VA) RATING	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT				CIRCUIT BREAKER				CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT		
												AB	BC	CA	3Ø	F	P	AT	AF	CONDUCTOR	GROUNDING	CONDUIT
APB1	C1	ACCU 1-01			1	3TR	230	5175	5175	1.00	5175	22.50	-	-	-	60	2	40	50	2 - 8.0 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	20 mm Ø Conduit - EMT
	C2	ACCU 1-01			1	3TR	230	5175	5175	1.00	5175	22.50	-	-	-	60	2	40	50	2 - 8.0 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	20 mm Ø Conduit - EMT
	C3	ACCU 1-02			1	3TR	230	5175	5175	1.00	5175	-	-	22.50	-	60	2	40	50	2 - 8.0 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	20 mm Ø Conduit - EMT
	C4	ACCU 1-02			1	3TR	230	5175	5175	1.00	5175	-	-	22.50	-	60	2	40	50	2 - 8.0 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	20 mm Ø Conduit - EMT
	C5	ACCU 1-03			1	3TR	230	5175	5175	1.00	5175	-	22.50	-	-	60	2	40	50	2 - 8.0 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	20 mm Ø Conduit - EMT
	C6	ACCU 1-03			1	3TR	230	5175	5175	1.00	5175	-	22.50	-	-	60	2	40	50	2 - 8.0 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	20 mm Ø Conduit - EMT
	C7	ACCU 1-04			1	3TR	230	5175	5175	1.00	5175	22.50	-	-	-	60	2	40	50	2 - 8.0 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	20 mm Ø Conduit - EMT
	C8	ACCU 1-04			1	3TR	230	5175	5175	1.00	5175	22.50	-	-	-	60	2	40	50	2 - 8.0 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	20 mm Ø Conduit - EMT
	C9	ACCU 1-05			1	3	230	3910	3910	1.00	3910	-	-	17.00	-	60	2	30	50	2 - 8.0 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	20 mm Ø Conduit - EMT
	C10	ACCU 1-05			1	3	230	3910	3910	1.00	3910	-	-	17.00	-	60	2	30	50	2 - 8.0 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	20 mm Ø Conduit - EMT
	C11	ACCU 1-06			1	4TR	230	6440	6440	1.00	6440	-	28.00	-	-	60	2	50	50	2 - 14 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	25 mm Ø Conduit - EMT
	C12	ACCU 1-07			1	4TR	230	6440	6440	1.00	6440	-	28.00	-	-	60	2	50	50	2 - 14 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	25 mm Ø Conduit - EMT
	C13	SPARE					230	1500	1500	0.80	1200	5.22	-	-	-	60	2	20	50	-	-	-
	C14	SPARE					230	1500	1500	0.80	1200	5.22	-	-	-	60	2	20	50	-	-	-
	C15	SPACE					-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	C16	SPACE					-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TOTAL			0	0	12		230		65100	0.99	64500	100.43	101.00	79.00	0.00							

Calculation:

For Feeder Conductor
 $I_c = [(6440 \times 125\%) + 55660 + 2400] / (230 \times \sqrt{3})$
 $I_c = 165.95 \text{ A}$

For Feeder Protection
 $I_{cb} = [(6440 \times 225\%) + 55660 + 2400] / (230 \times \sqrt{3})$
 $I_{cb} = 182.12 \text{ A}$

FEEDER CONDUCTOR
 3 - 10 mm² THHN CU (L) + 1 - 22 mm² THHN CU (G) @ 50 mm Ø EMT
 FEEDER PROTECTION
 USE: 200AT/250AF, 230V, 60HZ, 3P, Molded Case Circuit Breaker (MCCB)
 USE: 40kA, 3P, Type 2, Surge Protective Device (SPD)

ACU PANEL BOARD 2 - SCHEDULE OF LOADS

PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE RATING	OUTLET (VA) RATING	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT				CIRCUIT BREAKER				CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT		
												AB	BC	CA	3Ø	F	P	AT	AF	CONDUCTOR	GROUNDING	CONDUIT
APB2	C1	ACCU 2-01			1	4TR	230	6440	6440	1.00	6440	28.00	-	-	-	60	2	50	50	2 - 14 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	25 mm Ø Conduit - EMT
	C2	ACCU 2-01			1	4TR	230	6440	6440	1.00	6440	28.00	-	-	-	60	2	50	50	2 - 14 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	25 mm Ø Conduit - EMT
	C3	ACCU 2-02			1	4TR	230	6440	6440	1.00	6440	-	-	28.00	-	60	2	50	50	2 - 14 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	25 mm Ø Conduit - EMT
	C4	ACCU 2-02			1	4TR	230	6440	6440	1.00	6440	-	-	28.00	-	60	2	50	50	2 - 14 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	25 mm Ø Conduit - EMT
	C5	ACCU 2-03			1	4TR	230	6440	6440	1.00	6440	-	28.00	-	-	60	2	50	50	2 - 14 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	25 mm Ø Conduit - EMT
	C6	ACCU 2-03			1	4TR	230	6440	6440	1.00	6440	-	28.00	-	-	60	2	50	50	2 - 14 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	25 mm Ø Conduit - EMT
	C7	ACCU 2-04			1	4TR	230	6440	6440	1.00	6440	28.00	-	-	-	60	2	50	50	2 - 14 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	25 mm Ø Conduit - EMT
	C8	ACCU 2-04			1	4TR	230	6440	6440	1.00	6440	28.00	-	-	-	60	2	50	50	2 - 14 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	25 mm Ø Conduit - EMT
	C9	ACCU 2-05			1	4TR	230	6440	6440	1.00	6440	-	-	28.00	-	60	2	50	50	2 - 14 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	25 mm Ø Conduit - EMT
	C10	ACCU 2-05			1	4TR	230	6440	6440	1.00	6440	-	-	28.00	-	60	2	50	50	2 - 14 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	25 mm Ø Conduit - EMT
	C11	ACCU 2-06			1	3	230	1840	1840	1.00	1840	-	8.00	-	-	60	2	30	50	2 - 5.5 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C12	ACCU 2-07			1	3	230	3910	3910	1.00	3910	-	17.00	-	-	60	2	30	50	2 - 5.5 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C13	ACCU 2-08			1	2.5	230	3335	3335	1.00	3335	14.50	-	-	-	60	2	30	50	2 - 5.5 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	15 mm Ø Conduit - EMT
	C14	ACCU 2-09			1	4TR	230	6440	6440	1.00	6440	28.00	-	-	-	60	2	50	50	2 - 14 mm ² THHN Copper Wire	1 - 5.5 mm ² THHN Copper Wire	25 mm Ø Conduit - EMT
	C15	SPARE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
	C16	SPACE					230	1500	1500	0.80	1200	-	-	5.22	-	60	2	20	50	-	-	-
TOTAL			0	0	14		230		82925	0.99	82325	154.50	81.00	122.43	0.00							

Calculation:

For Feeder Conductor
 $I_c = [(6440 \times 125\%) + 73485 + 2400] / (230 \times \sqrt{3})$
 $I_c = 210.7 \text{ A}$

For Feeder Protection
 $I_{cb} = [(6440 \times 225\%) + 73485 + 2400] / (230 \times \sqrt{3})$
 $I_{cb} = 226.86 \text{ A}$

FEEDER CONDUCTOR
 USE: 3 - 150 mm² THHN CU (L) + 1 - 22 mm² THHN CU (G) @ 65 mm Ø EMT
 FEEDER PROTECTION
 USE: 250AT/250AF, 230V, 60HZ, 3P, Molded Case Circuit Breaker (MCCB)
 USE: 40kA, 3P, Type 2, Surge Protective Device (SPD)

ACU PANEL BOARD 1

LOAD TYPE	DEMAND VA	DEMAND CURRENT			
		AB	BC	CA	3Ø
LIGHTING OUTLET	0.00	0.00	0.00	0.00	0.00
CONVENIENCE OUTLET	0.00	0.00	0.00	0.00	0.00
AIR CONDITIONING UNIT	55660.00	90.00	73.00	79.00	0.00
MOTOR	0.00	0.00	0.00	0.00	0.00
LARGEST AIR CONDITIONING UNIT	6440.00	0.00	28.00	0.00	0.00
LARGEST MOTOR	0.00	0.00	0.00	0.00	0.00
SPARE	2400.00	10.43	0.00	0.00	0.00
TOTAL	64500.00	100.43	101.00	79.00	0.00

ACU PANEL BOARD 2

LOAD TYPE	DEMAND VA	DEMAND CURRENT			
		AB	BC	CA	3Ø
LIGHTING OUTLET	0.00	0.00	0.00	0.00	0.00
CONVENIENCE OUTLET	0.00	0.00	0.00	0.00	0.00
AIR CONDITIONING UNIT	73485.00	126.50	81.00	112.00	0.00
MOTOR	0.00	0.00	0.00	0.00	0.00
LARGEST AIR CONDITIONING UNIT	6440.00	28.00	0.00	0.00	0.00
LARGEST MOTOR	0.00	0.00	0.00	0.00	0.00
SPARE	2400.00	0.00	0.00	10.43	0.00
TOTAL	82325.00	154.50	81.00	122.43	0.00



REPUBLIC OF THE PHILIPPINES
UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES
CAGAYAN DE ORO CAMPUS
INFRASTRUCTURE PLANNING AND FACILITY DEVELOPMENT UNIT
CLARO M. RECTO AVENUE, LAPASAN, CAGAYAN DE ORO CITY 9000
TELEPHONE: (08822) 72-60-65 / (088) 856-1738 / 856-1739 | TELE FAX (088) 856-4696
WEBSITE: www.ustp.edu.ph

PROFESSIONAL ELECTRICAL ENGINEER

PROJECT

PROPOSED ESTABLISHMENT OF 3-STORY SMART COMPUTING
ACADEMIC BUILDING PHASE 1, OROQUIETA CAMPUS

LOCATION

USTP OROQUIETA CAMPUS, MORBO, MISAMIS OCCIDENTAL

OWNER

UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES

RECOMMENDING APPROVAL:

ENGR. GRACE C. BABA
DIRECTOR, INFRASTRUCTURE PLANNING & FACILITIES DEVELOPMENT OFFICE

RECOMMENDING APPROVAL:

DR. CLORIMER L. CLARIN
CAMPUS DIRECTOR, USTP OROQUIETA CAMPUS

APPROVED BY:

ATTY. JONATHAN S. OCHE
VP FOR ADMINISTRATION & LEGAL AFFAIRS

APPROVED BY:

DR. AMBROSIO B. CULTURA II
PRESIDENT, USTP SYSTEM

SHEET CONTENTS:
SCHEDULE OF LOADS

DRAWN BY:

DATE DRAWN:
05.01.2026
FNT:

E15

ACU PANEL BOARD 3 - SCHEDULE OF LOADS

PANEL NO.	CKT NO.	LOAD DESCRIPTION	L.O.	C.O.	OTHER LOADS	HP RATING	VOLTAGE RATING	OUTLET (VA) RATING	VA PER CIRCUIT	DEMAND FACTOR	DEMAND VA	CIRCUIT LOAD CURRENT				CIRCUIT BREAKER				CIRCUIT CONDUCTOR, GROUNDING, AND CONDUIT		
												AB	BC	CA	3Ø	F	P	AT	AF	CONDUCTOR	GROUNDING	CONDUIT
APB3	C1	ACCU 3-01			1	6TR	230	8206	8206	1.00	8206	-	-	-	20.60	60	3	40	50	3 - 8.0 mm² THHN Copper Wire	1 - 5.5 mm² THHN Copper Wire	25 mm ø Conduit - EMT
	C2	ACCU 3-01			1	6TR	230	8206	8206	1.00	8206	-	-	-	20.60	60	3	40	50	3 - 8.0 mm² THHN Copper Wire	1 - 5.5 mm² THHN Copper Wire	25 mm ø Conduit - EMT
	C3	ACCU 3-01			1	6TR	230	8206	8206	1.00	8206	-	-	-	20.60	60	3	40	50	3 - 8.0 mm² THHN Copper Wire	1 - 5.5 mm² THHN Copper Wire	25 mm ø Conduit - EMT
	C4	ACCU 3-06			1	6TR	230	8206	8206	1.00	8206	-	-	-	20.60	60	3	40	50	3 - 8.0 mm² THHN Copper Wire	1 - 5.5 mm² THHN Copper Wire	25 mm ø Conduit - EMT
	C5	ACCU 3-07			1	5TR	230	7131	7131	1.00	7131	-	-	-	17.90	60	3	40	50	3 - 8.0 mm² THHN Copper Wire	1 - 5.5 mm² THHN Copper Wire	25 mm ø Conduit - EMT
	C6	ACCU 3-02			1	1	230	1840	1840	1.00	1840	8.00	-	-	-	60	2	30	50	2 - 5.5 mm² THHN Copper Wire	1 - 5.5 mm² THHN Copper Wire	15 mm ø Conduit - EMT
	C7	ACCU 3-03			1	4TR	230	6440	6440	1.00	6440	28.00	-	-	-	60	2	50	50	2 - 14 mm² THHN Copper Wire	1 - 5.5 mm² THHN Copper Wire	25 mm ø Conduit - EMT
	C8	ACCU 3-03			1	4TR	230	6440	6440	1.00	6440	-	-	28.00	-	60	2	50	50	2 - 14 mm² THHN Copper Wire	1 - 5.5 mm² THHN Copper Wire	25 mm ø Conduit - EMT
	C9	ACCU 3-04			1	1	230	1840	1840	1.00	1840	-	-	8.00	-	60	2	30	50	2 - 5.5 mm² THHN Copper Wire	1 - 5.5 mm² THHN Copper Wire	15 mm ø Conduit - EMT
	C10	ACCU 3-05			1	4TR	230	6440	6440	1.00	6440	-	-	28.00	-	60	2	50	50	2 - 14 mm² THHN Copper Wire	1 - 5.5 mm² THHN Copper Wire	25 mm ø Conduit - EMT
TOTAL	C11	SPARE					230	1500	1500	0.80	1200	-	5.22	-	60	2	20	50	-	-	-	
	C12	SPARE					230	1500	1500	0.80	1200	5.22	-	-	60	2	20	50	-	-	-	
	C13	SPACE					-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	C14	SPACE					-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	C15	SPACE					-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	C16	SPACE					-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
TOTAL			0	0	10		230		65957	0.99	65357	41.22	33.22	36.00	100.30							

ACU PANEL BOARD 3					
LOAD TYPE	DEMAND VA	DEMAND CURRENT			
		AB	BC	CA	3Ø
LIGHTING OUTLET	0.00	0.00	0.00	0.00	0.00
CONVENIENCE OUTLET	0.00	0.00	0.00	0.00	0.00
AIR CONDITIONING UNIT	56516.68	0.00	28.00	36.00	100.30
MOTOR	0.00	0.00	0.00	0.00	0.00
LARGEST AIR CONDITIONING UNIT	6440.00	28.00	0.00	0.00	0.00
LARGEST MOTOR	0.00	0.00	0.00	0.00	0.00
SPARE	2400.00	5.22	5.22	0.00	0.00
	65356.68	33.22	33.22	36.00	100.30

Calculation:

For Feeder Conductor
 $I_c = [(6440 \times 125\%) + 56516.68 + 2400] / (230 \times \sqrt{3})$
 $I_c = 168.1 \text{ A}$

For Feeder Protection
 $I_{cb} = [(6440 \times 225\%) + 56516.68 + 2400] / (230 \times \sqrt{3})$
 $I_{cb} = 184.27 \text{ A}$

FEEDER CONDUCTOR

USE: 3 - 100 mm² THHN CU (L) + 1 - 22 mm² THHN (S) @ 50% EMT

FEEDER PROTECTION

USE: 200AT/250A, 60HZ, 3P, Molded Case Circuit Breaker (MCCB)

USE: 40kA Type Z, Surge Protective Device (SPD)

TRANSFORMER TO SERVICE BUS

LENGTH	15	m
FLC	1306.20	A
SETS	4	
PHASE	3	
FACTOR	1.732	
CONDUCTOR		
	325mm ²	
RESISTANCE	0.025	Ω
REACTANCE	0.048	Ω
COMPUTATION	$VD = [1.732 \times (1306.2/4) \times \sqrt{(0.025^2 + 0.048^2)}] / 305m \times 15m$	
VOLTAGE DROP	1.505383161	V

SERVICE BUS TO ATS

LENGTH	10	m
FLC	1306.20	A
SETS	4	
PHASE	3	
FACTOR	1.732	
CONDUCTOR		
	325mm ²	
RESISTANCE	0.025	Ω
REACTANCE	0.048	Ω
COMPUTATION	$VD = [1.732 \times (1306.2/4) \times \sqrt{(0.025^2 + 0.048^2)}] / 305m \times 10m$	
VOLTAGE DROP	1.003588774	V

MDP

LENGTH	30	m
FLC	1306.20	A
SETS	4	
PHASE	3	
FACTOR	1.732	
CONDUCTOR		
	325mm ²	
RESISTANCE	0.025	Ω
REACTANCE	0.048	Ω
COMPUTATION	$VD = [1.732 \times (1306.2/4) \times \sqrt{(0.025^2 + 0.048^2)}] / 305m \times 30m$	
VOLTAGE DROP	3.010766322	V

MDP TO APB3

LENGTH	15	m
FLC	164.06	A
SETS	3	
PHASE	3	
FACTOR	1.732	
CABLE		
	100mm ²	
RESISTANCE	0.063	Ω
REACTANCE	0.051	Ω
COMPUTATION	$VD = [1.732 \times (164.06/3) \times \sqrt{(0.063^2 + 0.051^2)}] / 305m \times 15m$	
VOLTAGE DROP	0.77575186	V


APB3 TO FARTHEST MOTOR LOAD (CKT1)

LENGTH	30	m
FLC	20.60	A
SETS	1	
PHASE	3	
FACTOR	1.732	
CABLE		
	8mm ²	
RESISTANCE	0.15	Ω
REACTANCE	0.046	Ω
COMPUTATION	$VD = [1.732 \times (20.6/1) \times \sqrt{(0.15^2 + 0.046^2)}] / 305m \times 30m$	
VOLTAGE DROP	0.550611484	V

VOLTAGE DROP ANALYSIS

TOTAL VOLTAGE DROP FROM SERVICE TO FARTHEST LOAD	1.51 + 1 + 3.01 + 0.38 + 0.55	6.45 V	PERCENT VOLTAGE DROP
VOLTAGE DROP COMPUTATION USING NOMINAL VOLTAGE (240V)	240 - 6.45 V	233.55	2.69%

DISTRIBUTION



VOLTAGE DROP ANALYSIS

SCALE:

NTS



REPUBLIC OF THE PHILIPPINES
UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES
INFRASTRUCTURE PLANNING AND FACILITY DEVELOPMENT UNIT
CLARO H. RECTO AVENUE, LAPASAN, CAGAYAN DE ORO CITY 9000
TELEPHONE: W (08822) 72-60-65 / (088) 856-1738 / 856-1739 | TELE FAX (088) 856-4896
WEBSITE: www.ustp.edu.ph

PROFESSIONAL ELECTRICAL ENGINEER

PROJECT

PROPOSED ESTABLISHMENT OF 3-STORY SMART COMPUTING
ACADEMIC BUILDING PHASE 1, OROQUIETA CAMPUS

LOCATION

USTP OROQUIETA CAMPUS, MOROD, MISAMIS OCCIDENTAL

OWNER

UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES

RECOMMENDING APPROVAL:

ENGR. GRACE C. BABA

DIRECTOR, INFRASTRUCTURE PLANNING & FACILITIES DEVELOPMENT OFFICE

RECOMMENDING APPROVAL:

DR. GLORIMER L. CLARIN

CAMPUS DIRECTOR, USTP OROQUIETA CAMPUS

APPROVED BY:

ATTY. JONATHAN S. OCHE

VP FOR ADMINISTRATION & LEGAL AFFAIRS

APPROVED BY:

DR. AMBROSIO B. CULTURA II

PRESIDENT, USTP SYSTEM

SHEET CONTENTS:
SCHEDULE OF LOADS
VOLTAGE DROP ANALYSIS

DRAWN BY:

DATE DRAWN:

05.01.2026

ENT:

E16

USING POINT TO POINT METHOD

Transformer Full Load Current (I_{FLA})

1. For 3Ø System:

$$f = (1.732 \times L \times I_{sc}) / (C \times n \times E_{L-L})$$

For 3Ø Transformer:

$$I_{FLA} = (kVA \times 1000) / (E_{L-L} \times \sqrt{3})$$

For 1Ø Transformer:

$$I_{FLA} = (kVA \times 1000) / E_{L-L}$$

2. For Line-to-Line:

$$f = (2 \times L \times I_{L-L}) / (C \times n \times E_{L-L})$$

3. For Line-to-Neutral: $f = (2 \times L \times I_{L-N}) / (C \times n \times E_{L-N})$

Multiplier = $100 / (\%Z_{transformer})$

$$M = 1 / (1 + f)$$

$$I_{S.C.sym.RMS} = I_{S.C.} \times M$$

$$I_{S.C. Motor Contribution} = I_{S.C.} \times 4$$

TRANSFORMER RATING	750	kVA
%Z	2	(Typical Value)
PRIMARY LINE VOLTAGE	13.2	kV
SECONDARY LINE VOLTAGE	240	V

MOTOR LOADS		
TYPE	FLC	SHORT CIRCUIT CURRENT CONTRIBUTION (kA)
AIRCON	891.22	3.56
MOTOR (NON CONTINUOUS)	67.03	0.27
MOTOR (CONTINUOUS)	0.00	0.00
LARGEST MOTOR	72.75	0.29
TOTAL MOTOR CONTRIBUTION		4.12

GENERATOR						
RATING		PF	VOLTAGE	FLC	SUBTRANSIENT REACTANCE (%)	SHORT CIRCUIT CURRENT CONTRIBUTION (kA)
kVA	kW					
300	240	0.8	240	721.709007	25%	2.89

SHORT CIRCUIT ANALYSIS			
FAULT NO.	FAULT LOCATION	TOTAL 3P FAULT CURRENT (kA)	MINIMUM CB KAIC RATING
1	XMER SECONDARY SIDE	104.36	
2	SERVICE BUS	76.37	85
3	ATS	61.53	85
4	ATS-FPP	23.87	30
5	FPP	6.71	18
5	MDP	36.47	50

FAULT LOCATION 1		
XMER SECONDARY SIDE		
TRANSFORMER FLC	1804.272517	A
MULTIPLIER	55.55555556	
3P FAULT CURRENT	100237.3621	A
	100.2373621	kA
TOTAL 3P FAULT CURRENT	104361.382	A
	104.361382	kA

FAULT LOCATION 2		
SERVICE BUS		
CONDUCTOR	325	mm2
NO. OF SETS	4	
LENGTH	15	m
C VALUE	22965	
"f" FACTOR	0.387539639	
MULTIPLIER	0.720700131	
3P FAULT CURRENT	72241.07999	A
	72.24107999	kA
TOTAL 3P FAULT CURRENT	76365.09991	A
	76.36509991	kA

FAULT LOCATION 3		
ATS		
CONDUCTOR	325	mm2
NO. OF SETS	4	
LENGTH	10	m
C VALUE	22965	
"f" FACTOR	0.25835976	
MULTIPLIER	0.794685298	
3P FAULT CURRENT	57408.92414	A
	57.40892414	kA
TOTAL 3P FAULT CURRENT	61532.94407	A
	61.53294407	kA

FAULT LOCATION 4		
ATS-FPP		
CONDUCTOR	50	mm2
NO. OF SETS	1	
LENGTH	10	m
C VALUE	8925	
"f" FACTOR	2.659151543	
MULTIPLIER	0.273287397	
3P FAULT CURRENT	19742.5767	A
	19.7425767	kA
TOTAL 3P FAULT CURRENT	23866.59663	A
	23.86659663	kA

FAULT LOCATION 5		
FPP		
CONDUCTOR	50	mm2
NO. OF SETS	1	
LENGTH	25	m
C VALUE	8925	
"f" FACTOR	6.647878856	
MULTIPLIER	0.130755209	
3P FAULT CURRENT	2581.444747	A
	2.581444747	kA
TOTAL 3P FAULT CURRENT	6705.464674	A
	6.705464674	kA


FAULT LOCATION 6		
MDP		
CONDUCTOR	325	mm2
NO. OF SETS	4	
LENGTH	30	m
C VALUE	22965	
"f" FACTOR	0.775079279	
MULTIPLIER	0.56335512	
3P FAULT CURRENT	32341.61135	A
	32.34161135	kA
TOTAL 3P FAULT CURRENT	36465.63127	A
	36.46563127	kA

DISTRIBUTION

UTILITY

$V_p = 13.2kV/7.62kV$
Wye - Grounded


3 x 250kVA 3Ø
 $V_s = 240V$
 $\%Z = 2\%$



SHORT CIRCUIT ANALYSIS

SCALE:

NTS



REPUBLIC OF THE PHILIPPINES
UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES
CAGAYAN DE ORO CAMPUS
INFRASTRUCTURE PLANNING AND FACILITY DEVELOPMENT UNIT
CLARO M. RECTO AVENUE, LAPASAN, CAGAYAN DE ORO CITY 9000
TELEPHONE # (0822) 72-60-05 / (088) 856-1738 / 856-1739 | TELE FAX (088) 856-4696
WEBSITE: www.ustp.edu.ph

PROFESSIONAL ELECTRICAL ENGINEER

PROJECT

LOCATION

OWNER

PROPOSED ESTABLISHMENT OF 3-STORY SMART COMPUTING
ACADEMIC BUILDING PHASE 1, OROQUIETA CAMPUS

USTP OROQUIETA CAMPUS, MOBOO, MISAMIS OCCIDENTAL

UNIVERSITY OF SCIENCE AND TECHNOLOGY OF SOUTHERN PHILIPPINES

RECOMMENDING APPROVAL:

ENGR. GRACE C. BABA

DIRECTOR, INFRASTRUCTURE PLANNING &
FACILITIES DEVELOPMENT OFFICE

RECOMMENDING APPROVAL:

DR. GLOMER L. CLARIN

CAMPUS DIRECTOR, USTP OROQUIETA CAMPUS

APPROVED BY:

ATTY. JONATHAN S. OCHE

VP FOR ADMINISTRATION & LEGAL AFFAIRS

APPROVED BY:

DR. AMBROSIO B. CULTURA II

PRESIDENT, USTP SYSTEM

SHEET CONTENTS:

SHORT CIRCUIT ANALYSIS

DRAWN BY:

DATE DRAWN:

05.01.2026

PRINT:

E17