



University of Science and Technology of Southern Philippines

Alubijid | Cagayan de Oro | Claveria | Jasaan | Oroquieta | Panaon

INVITATION /REQUEST FOR SUBMISSION OF PRICE QUOTATION
Posted in PhilGEPS Website/Conspicuous Place at the Procuring Entity

The University of Science & Technology of Southern Philippines, through the Bids and Awards Committee (BAC) hereby invites interested parties to submit quotation for the procurement of the following item:

Reference No.	Qty.	Unit	Specification/Description	Budget for the Contract	Mode of Procurement
RFQ-NP-SVP-090-2021	Please see details below	Please see details below	Negotiated Procurement for Procurement for Generator Parts	₱76,450.00	Small Value Procurement- Section 53.9, Rule XVI, Revised IRR of RA 9184)

Deadline for the submission of quotation is on March 29, 2021 at 12:00 noon at the Procurement Unit, 2nd Floor, USTP Gymnasium building. You may submit your quotation through fax number 856-4696 / 856-1739 or through personal delivery in a sealed envelope.

The University of Science & Technology of Southern Philippines reserves the right to accept or reject any or all bids / price quotations, to annul the process, and to reject all bids at any time prior to contract award, without thereby incurring any liability to the affected bidder or bidders.


ENGR. ARNEL L. MAUREAL
BAC I Chairman



Date: March 24, 2021
 Quotation No.: RFQ-NP-SVP-090-2021

Name of Project: Procurement for
 Generator Parts

The Manager

Cagayan de Oro City

Please quote your lowest price on the item/s listed below, subject to the general Conditions stated below, stating the shortest time of delivery and submit your quotation duly signed by your representative not later than March 29, 2021 at 12:00 noon. Please enclosed in a sealed envelope.

ENGR. ALEX L. MAUREAL
 BAC 1 Chairman

- NOTE:
1. DELIVERY PERIOD WITHIN 7 CALENDAR DAYS UPON RECEIPT OF PO.
 2. PRICE VALIDITY SHALL BE FOR A PERIOD OF 30 CALENDAR DAYS
 3. BIDDERS SHALL SUBMIT ORIGINAL BROCHURES SHOWING CERTIFICATIONS OF THE PRODUCT BEING OFFERED (if applicable)
 4. THE USTP RESERVES THE RIGHT TO REJECT ANY OR ALL BIDS FOR ANY JUSTIFIABLE AND REASONABLE GROUND WHERE THE AWARD OF THE CONTRACT WILL NOT REDOUND TO THE BENEFIT OF THE GOP.
 5. REQUIREMENTS: 1) PHILGEPS REGISTRATION (PLATINUM MEMBERSHIP).

ITEM #	QTY	UNIT	DESCRIPTIONS AND SPECIFICATIONS	APPROVED UNIT COST (php)	UNIT PRICE
1	1	unit	$\pm 0.5\text{0A}$, Regulation - 220/ 400 VAC Programmable Input, Rugged Compact Design, with Under Frequency Protection, Soft Start Voltage Ramping, Emf Suppression, Built-in High Capacity 15 Amp Fuse, Sensing Input Voltage, 220/ 400VAC, 1 phase 2 wire, Power In-put Voltage 180-240VAC input, Current Continuous 6A, Intermittent 12A for 10SEE, Resistance Min. 10 Ω Max 100 Ω , Voltage Buil-up esidualvolts at AVR terminal>5VAC, External Volys Adjustment +/-7% with 1K Ω 1 watt trimmer, Unit Power Dissipation Max. 8watt, Under Frequency Protection 60Hz system presets knee point at 57Hz. (Including Installation)	28,600.00	
2	1	unit	GENSET CONTROLLER DGS6110UC Specifications: Material: Plastic Weight: 695g/ 24.5oz Model: DGS6110UC Normal delay of mains voltage: (0-3600)s Abnormal delay of mains voltage: (0-3600)s Low voltage value: (30-620)V Threshold of high mains voltage: (30-620)V Switching interval: (0-99.9)s Startup delay: (0-3600)s Stop delay: (0-3600)s Starting time: (1-10)times Preheating time: (3-300)s Strting time: (3-60)s Starting interval: (3-60)s Safe running time: (1-60)s Boot idle time: (0-3600)s High-speed warm-up time: (0-3600)s High-speed cooling time: (0-3600)s Idle time: (0-3600)s Downtime: (0-120)s Waiting stop delay: (0-120)s Switch closing delay: (0-10)s Engine teeth: (10-300)pcs	47,850.00	

Abnormal generation delay: (0-20.0)s
Threshold of generating overvoltage shutdown: (30-620)V
Power generation under voltage shutdown threshold: (30-620)V
Under speed stop threshold: (0-6000)RPM
Over speed stop threshold: (0-6000)RPM
Under frequency stop threshold: (0-75.0)Hz
Over frequency stop threshold: (0-75.0)Hz
Low oil pressure stop value: (0-400)kPa
Fuel level too low threshold: (0-100)%
Speed signal loss delay: (0-20.0)s
Charging failure threshold: (0-30)V
Battery overvoltage threshold: (12-40)V
Battery undervoltage threshold: (4-30)V
(Including Installation)

Delivery Period:

Price Validity:

After having carefully read and accepted for General Conditions, I/We quote on the item at prices noted above.

Rodorocio-Generator Parts
 RFQ-NP-SVP-090-2021
 Resolution No. 107 s. 2020
 PR No. 114-2021

 Tel. #/address/e-mail add

 Date

C.M. Recto Avenue, Lapasan, Cagayan de Oro City 9000 Philippines, Tel. Nos. +63 (88) 856 1738, Telefax +63 (88) 856 4696 | www.ustp.edu.ph